

15 KV

COOPER

CONNECTOR 4/0 AWG
COOPER CC6A16U

2.67" [2 11/16"]

9.77" [9 3/4"]

5-4 PRE-SWAGE
INJECTION ADAPTER (IA)

INSULATION CUT
BACK TEMPLATE

TOOL STOP

INSULATION
220 MILS

SEMI-CON SHIELD

6.30" [6 5/16"]

10.77" [10 3/4"]

4.45" [4 7/16"]

COOPER® BT625 T-BODY

MARKING TAPE

SEMI-CON SHIELD

CABLE INSULATION
ADAPTER CA625-D

TOOL STOP CUT
BACK TEMPLATE

**NOTE: THE INSULATION ADAPTER MUST
BE ON THE CABLE BEFORE SWAGING THE
CONNECTOR. SEE NRI 31 & NRI 32**

The marking tape must be located from end of strip cable (as shown as pre-swage) to the end of cable insulation adapter and should be within 1/4 inch [6mm] after swage.

CPR-15 BT625D 40 5-4 5mar10

© Copyright 2007, Novinium, Inc. All rights reserved.
IA is protected by patents and patents pending
COOPER is a registered trademark of Cooper Powere Systems. novinium is a registered trademark of novinium.
(Printing Instructions: For best results, print in color, protect w/5mil laminate and trim to size.)



SCALE: 1:1 8.5 x 22 paper size