

RICHARDS
15KV

CONNECTOR 750 AWG
RICHARDS P6AL-23

2.56" [2 9/16"]

9.71" [9 11/16"]

INSULATION
220 MILS

**INSULATION CUT
BACK TEMPLATE**

SEMI-CON SHIELD

TOOL STOP

6.22" [6 3/16"]

4.43" [4 7/16"]

11-10 PRE-SWAGE
INJECTION ADAPTER (IA)

10.71" [10 11/16"]

MARKING TAPE

RICHARDS 62LCN1 or 62LCT1

SEMI-CON SHIELD

CABLE INSULATION ADAPTER
RICHARDS P625CA-M

**TOOL STOP CUT
BACK TEMPLATE**

**NOTE, THE INSULATION ADAPTER MUST
BE ON THE CABLE BEFORE SWAGING THE
CONNECTOR. SEE NRI 31 & NRI 32**

The marking tape must be located from end of strip cable (as shown as pre-swage) to the end of cable insulation adapter and should be within 1/4 inch [6mm] after swage.

RCH-15 62LC(N-T)1-M 750 11-10 26mar10

© Copyright 2007, Novinium, Inc. All rights reserved.
IA is protected by patents and patents pending.
RICHARDS is a registered trademark of Richards Mfg. Novinium is a registered trademark of Novinium.
(Printing Instructions: For best results, print in color, protect w/Small Laminate and trim to size.)

novinium

SCALE: 1:1 8.5 x 22 paper size