

**RICHARDS**  
**25KV**

CONNECTOR 250 AWG  
RICHARDS P6AL-13

9.74" [9 3/4"]

2.58" [2 9/16"]

7-6 PRE-SWAGE (IA)  
INJECTION ADAPTER

INSULATION CUT  
BACK TEMPLATE

TOOL STOP

INSULATION  
260 MILS

SEMI-CON SHIELD

6.21" [6 3/16"]

10.74" [10 3/4"]

MARKING TAPE

4.45" [4 7/16"]

RICHARDS 62LCN1 or 62LCT1

SEMI-CON SHIELD

CABLE INSULATION ADAPTER  
RICHARDS P625CA-J

TOOL STOP CUT  
BACK TEMPLATE

**NOTE, THE INSULATION ADAPTER MUST  
BE ON THE CABLE BEFORE SWAGING THE  
CONNECTOR. SEE NRI 31 & NRI 32**

The marking tape must be located from end of strip cable (as shown as pre-swage) to the end of cable insulation adapter and should be within 1/4 inch [6mm] after swage.

RCH-25 62LC(N-T)1-J 250 7-6 26mar10

© Copyright 2007, Novinium, Inc. All rights reserved.

IA is protected by patents and patents pending

RICHARDS is a registered trademark of Richards Mfg. Novinium is a registered trademark of Novinium.

(Printing Instructions: For best results, print in color, protect w/5mil laminate and trim to size.)

SCALE: 1:1 8.5 x 22 paper size

**novinium**